

Comprehensive Guide to Low Voltage Earthing Systems: A Technical Analysis of Cahier Technique 172

Published: September 21, 2025 | Index ID: #591

In the complex landscape of electrical engineering, the design and implementation of Low Voltage (LV) earthing systems (also known as grounding systems) represent a fundamental pillar of both operational safety and system reliability. Drawing heavily from the foundational principles established in Schneider Electric's **Cahier Technique no. 172**, authored by B. Lacroix and R. Calvas, this article provides an exhaustive technical exploration of the various earthing arrangements utilized globally. Understanding these systems is not merely a matter of regulatory compliance; it is essential for protecting personnel, preventing equipment damage, and ensuring the continuity of service in critical industrial and commercial environments.

The Fundamental Role of Earthing in Low Voltage Networks

The primary objective of an earthing system is to connect specific points of an electrical circuit—typically the neutral point—to the ground and to connect the exposed conductive parts of the electrical equipment to the same ground. This configuration serves three main purposes: protecting people against electric shock (indirect contact), protecting the installation against fire and insulation failure, and providing a stable reference voltage for electronic equipment while mitigating electromagnetic disturbances.

As outlined in **Cahier Technique no. 172**, the choice of an earthing system influences the fault current magnitude, the touch voltage, and the protective device requirements. The International Electrotechnical Commission (IEC) standard 60364 defines three main families of earthing arrangements, identified by a two-letter code: **TN**, **TT**, and **IT**.

- First Letter: Relationship of the power system to earth (T = direct connection of one point to earth; I = all live parts isolated from earth or one point connected via an impedance).
- Second Letter: Relationship of the exposed-conductive-parts of the installation to earth (T = direct electrical connection to earth; N = direct electrical connection to the earthed point of the power system).

Technical Breakdown of the TT Earthing System

In a **TT system**, the neutral of the power source is connected directly to earth, and the exposed conductive parts of the load are connected to a separate earth electrode. This system is common in public distribution networks in many countries.

Fault Mechanism and Protective Strategy

When an insulation fault occurs in a TT system, the fault current (I_f) flows through the earth. The magnitude of this current is limited by the resistance of the source earth electrode (R_n) and the installation earth electrode (R_a). The formula for the fault current is expressed as:

$$I_f = U_o / (R_a + R_n)$$

Where U_o is the nominal phase-to-earth voltage. Because the resistance of the earth path is typically high enough to prevent a standard circuit breaker from tripping instantaneously, the **Residual Current Device (RCD)** is the mandatory protective component. The safety condition to prevent dangerous touch voltages (U_t) is defined

as:

$$R_a \times I_{\Delta n} \leq U_0$$

Typically, U_0 is set to 50V for dry environments. If the earth resistance R_a is 100 ohms, the RCD sensitivity ($I_{\Delta n}$) must be 500mA or less to ensure safety.

The TN Earthing System: TN-C, TN-S, and TN-C-S

The **TN system** connects the exposed conductive parts directly to the earthed point of the source (neutral) via a protective conductor (PE). This creates a low-impedance path, turning any insulation fault into a phase-to-neutral short circuit.

Variations of TN Architecture

- **TN-S (Separated):** The neutral (N) and protective conductor (PE) are separate throughout the system. This is the most reliable for electronic equipment as it prevents load currents from flowing through the PE conductor.
- **TN-C (Combined):** The neutral and protective functions are combined in a single conductor (PEN). While cost-effective, it is prohibited for small cross-sections (typically $\leq 10\text{mm}^2$ Cu or 16mm^2 Al) and is not recommended in buildings with sensitive data equipment due to circulating currents.
- **TN-C-S:** A hybrid where the system starts as TN-C and transitions to TN-S at the entry point of the installation.

Short-Circuit Analysis

In a TN system, the fault current is high: $I_f = U_0 / Z_s$, where Z_s is the impedance of the fault loop. Protection is ensured by overcurrent devices (circuit breakers or fuses). The disconnection time must be very short (e.g., 0.4 seconds for 230V systems) to prevent prolonged exposure to high touch voltages.

Deep Dive into the IT Earthing System (Unearthed Neutral)

The **IT system**, as detailed extensively in **Cahier Technique no. 172**, is the "unearthed" or "isolated" neutral system. Here, the source neutral is either completely isolated from earth or connected through a high impedance (typically 1,000 to 2,000 ohms). All exposed conductive parts are earthed.

The Advantage of the "First Fault"

The defining characteristic of the IT system is that during a single insulation fault, the fault current is extremely low (a few milliamps). This current is the vector sum of the leakage currents through the natural capacitance of the cables. Consequently, the touch voltage remains well below the safety limit (50V), and **there is no need for immediate disconnection**. This ensures maximum **continuity of service**, making IT the preferred choice for hospital operating theaters, continuous industrial processes, and data centers.

Managing the Second Fault

While the first fault is harmless, it must be located and cleared. If a second fault occurs on a different phase before the first is cleared, it results in a phase-to-phase short circuit, requiring immediate tripping by overcurrent devices. The **Permanent Insulation Monitor (PIM)** is the critical device in an IT system, used to alert maintenance staff as soon as the first fault occurs.

Technical Comparison of LV Earthing Systems

The following table provides a comparative analysis of the three systems based on the technical parameters identified in **Schneider Electric's study data**.

Feature	TT System	TN System	IT System
Neutral Connection	Directly earthed	Directly earthed	Isolated or High Impedance
Exposed Parts Connection	Separate earth electrode	Connected to Neutral (PE)	Earthed
Fault Current (1st Fault)	Medium (Amps)	High (Short-circuit)	Very Low (Milliamps)
Mandatory Protection	RCD	Circuit Breaker / Fuse	Insulation Monitor (PIM)
Continuity of Service	Low (Trips on 1st fault)	Low (Trips on 1st fault)	High (No trip on 1st fault)
Fire Risk	Low (with RCD)	High (High fault current)	Very Low
Maintenance Requirement	Low	Medium	High (Expertise needed)

Advanced Fault Detection: The Ground Fault Location System (GFLS)

In large industrial installations using the IT system, finding the source of a first fault can be challenging. As noted in **Cahier Technique no. 172** (specifically page 23 and 25), modern systems utilize an **LF (Low Frequency) generator** and **Current Sensors (CS)**. The generator injects a specific signal into the network; this signal flows through the fault point and back to the source. Toroidal current sensors placed on different feeders detect this signal, allowing the GFLS to pinpoint exactly which branch contains the insulation failure without de-energizing the system.

Mathematical Models for Fault Current Calculation

To accurately design protection schemes, engineers must calculate the maximum and minimum fault currents. The **Cahier Technique 172** provides the framework for these calculations:

1. IT System First Fault Current (I_{f1})

For an isolated neutral system, the current is mainly capacitive:

$$I_{f1} = U_o \times 3 \times C \times \omega$$

Where C is the average capacitance per phase to earth and ω is the angular frequency ($2\pi f$).

2. TN System Fault Current (I_{sc})

The fault current at the end of a cable run is calculated using the impedance method:

$$I_{sc} = (0.8 \times U_o) / (Z_{phase} + Z_{PE})$$

The 0.8 coefficient accounts for the voltage drop at the source during the fault. This calculation ensures that the magnetic trip setting of the circuit breaker is low enough to detect a fault at the furthest point of the circuit.

Dealing with Electrical Disturbances in LV Networks

As referenced in **Cahier Technique no. 141** and **172**, earthing systems also play a role in managing voltage drops and electromagnetic interference (EMI). Transient disturbances, such as lightning or switching surges, can cause significant damage if the earthing system is not designed with low high-frequency impedance.

Equipotential Bonding

Regardless of the earthing system chosen, **equipotential bonding** is mandatory. This involves connecting all metallic parts (pipes, frames, structures) to the main earthing terminal. This prevents potential differences between different surfaces, which is the root cause of electric shock and many EMI issues in sensitive electronics.

Practical Field Guide: Choosing the Right System

The selection of an earthing system is a strategic decision. Engineers should follow this procedural checklist based on the application requirements:

1. Assess the Need for Continuity: If a sudden power cut poses a risk to life (hospitals) or results in massive financial loss (semiconductor manufacturing), the IT system is mandatory.
2. Evaluate Maintenance Capabilities: The IT system requires an on-site electrical team capable of responding to first-fault alarms. If no such team exists, TT or TN is safer.
3. Consider the Installation Scale: For large-scale industrial sites with their own HV/LV transformers, TN-S provides a robust and cost-effective solution for high-power loads.
4. Analyze Electromagnetic Compatibility (EMC): In buildings with extensive IT infrastructure, avoid TN-C. The combined PEN conductor carries unbalanced load currents, which can couple into data cables and cause corruption. Use TN-S to ensure a "clean" PE conductor.

Case Study: Double Fault Scenarios in IT Systems

A common operational challenge in IT systems is the "second fault." Imagine an industrial plant where a motor develops an insulation fault on Phase A. The PIM alarms, but the motor continues to run. Before the technicians arrive, a second fault occurs on Phase B of a different machine.

This creates a phase-to-phase short circuit (400V in a $230/400\text{V}$ system). The current I_{f2} is calculated as:

$$I_{f2} = (\sqrt{3} \times U_o) / (2 \times Z_s)$$

Because the current is now very high, the circuit breakers for both faulty circuits must trip simultaneously. This case study highlights the importance of **selectivity** and **discrimination** in protection design to ensure that only the faulty sections are isolated, preserving power to the rest of the plant.

Implementation Challenges and Solutions

1. High Earth Resistance in TT Systems

In rocky or sandy terrain, achieving a low earth resistance (R_a) is difficult. **Solution:** Use multiple earth rods in parallel or chemical earth enhancement compounds. If R_a remains high, extremely sensitive RCDs (30mA) must be used, though this may lead to nuisance tripping from natural leakage currents.

2. Harmonic Distortions

Non-linear loads (VFDs, LED lighting) generate harmonics that flow through the neutral. In **TN-C** systems, these harmonics can cause the PEN conductor to overheat. **Solution:** Oversize the neutral conductor or switch to a **TN-S** system where the neutral is not used for earthing equipment frames.

3. Testing and Validation

Commissioning an earthing system requires precise measurement. The **"Fall of Potential"** method is the industry standard for measuring earth electrode resistance. For TN systems, **Loop Impedance Testing** is critical to verify

that the fault current will be high enough to trip breakers within the required timeframes.

The Evolution of Earthing Standards

The technical insights provided by **Cahier Technique no. 172** have shaped international standards for decades. As we transition toward decentralized energy resources (DERs), such as solar PV and battery storage, earthing becomes even more complex. Inverter-based resources often have different fault signatures compared to traditional synchronous generators, requiring more sophisticated protection coordination and a deeper understanding of the interaction between the source earthing and the local installation earthing.

In summary, the selection of an LV earthing system involves a delicate balance between safety, continuity, and cost. The TT system offers simplicity but relies heavily on RCDs. The TN system provides high-speed disconnection for faults but requires careful management of the PE/N conductors. The IT system offers unparalleled continuity but demands higher technical expertise for maintenance and fault location. By adhering to the engineering principles detailed in the Cahier Technique series, electrical professionals can design resilient networks that withstand insulation failures and minimize operational downtime.

Baca Juga (Artikel Terkait)

- [Comprehensive Guide to Digital Design: Principles and Practices for Modern Engineering](http://alghafgolden.com/comprehensive-guide-digital-design-principles-practices.pdf)

URL: <http://alghafgolden.com/comprehensive-guide-digital-design-principles-practices.pdf>

- [A Comprehensive Technical Guide to the Principles of Electric Circuits: Conventional Current Version](http://alghafgolden.com/comprehensive-guide-principles-of-electric-circuits-conventional-current.pdf)

URL: <http://alghafgolden.com/comprehensive-guide-principles-of-electric-circuits-conventional-current.pdf>

- [Comprehensive Guide to 1-Phase and 3-Phase Transformer Testing: Technical Methodologies and Diagnostic Frameworks](http://alghafgolden.com/comprehensive-guide-transformer-testing-mca-diagnostics.pdf)

URL: <http://alghafgolden.com/comprehensive-guide-transformer-testing-mca-diagnostics.pdf>

- [The Comprehensive Guide to LED Driver Technology: Constant Current vs. Constant Voltage Architectures](http://alghafgolden.com/comprehensive-guide-led-driver-technology-constant-current-vs-constant-voltage.pdf)

URL: <http://alghafgolden.com/comprehensive-guide-led-driver-technology-constant-current-vs-constant-voltage.pdf>

Tags: #Earthing Systems #Low Voltage #Cahier Technique 172 #IT System #Schneider Electric #Electrical Safety

